

the **innovation** and **valorization** formula



Materials
innovation
institute

Sustainable E+ Steel-frame Industrial Halls : **advanced design support and assessment**

Bruno Lee

PhD researcher

Supervised by :

prof.dr.ir Jan Hensen, prof.ir. Bert Snijder, Dr. John Bynum



Duurzaam bouwen met staal :

Jan 16, 2014


Contents:

- **Background**
- **Life-cycle Analysis**
- **Quick Screening Tool / Databases**
- **Design Trends**

Tremendous amount of energy consumed by the industrial sector ... and “Industrial Halls” are not limited to **FACTORIES**, but also :

- **WAREHOUSES,**
- **BIG-BOX RETAILERS** (eg. Ikea, Praxis ...),
- and many **SUPERMARKETS.**


Energy consumption in Europe



■ Household ■ Services ■ Industry ■ Transport


[source: Eurostat, 2009]

Energy consumption in the United States



■ Household ■ Commercial ■ Industry ■ Transportation

[source: LLNL, 2009]



[source: LLNL, 2009]

Less than 15% of the energy consumed by the industry is from


... Renewable Sources

High roof-to-floor ratio of typical industrial halls open up opportunities for incorporating renewable energy technologies, such as PV

What is Sustainability?

— the many aspects


- ▶ green building rating system (eg. LEED certification ... or BREEAM)



What is Sustainability?

— the many aspects


- ▶ green building rating system (eg. LEED certification ... or BREEAM)



Life-cycle Carbon Analysis
















total Life-cycle Carbon Emission concept:
considers Carbon Emission during the

Construction Phase + Operation Phase + Demolition Phase



What is a **typical** industrial halls?

- quite evenly distributed and relatively low process load

Subject or and Industry	Equivalent Process Load (W/m ²)	Portion of Energy consumed outside enclosure (if evenly distributed)	
Furniture and Related Products	23	0%	    <p>characteristics : low process energy, labour intensive</p>
Apparel	23	0%	
Plastics and Rubber Products	178	8%	
Fabricated Metal Products	103	10%	
Electrical Appliances, and Components	103	18%	    <p>characteristics : low-medium process energy, few workers, each oversees many lines</p>
Transportation Equipment	103	20%	
Computer and Electronic Products	65	26%	
Fruit and Vegetable Preserving	239	42%	
Textile Product Mills	92	2%	    
Foundries	231	6%	
Food	212	76%	
Paper	421	82%	
Chemicals	574	82%	 

Industrial Halls ...

- Chemical plants, metal foundries, paper making ...

> 70% of energy is consumed outside the enclosure

Subject or and Industry	Equivalent Process Load (W/m ²)	Portion of Energy consumed outside enclosure (if evenly distributed)
Furniture and Related Products	23	0%
Apparel	23	0%
Plastics and Rubber Products	178	8%
Fabricated Metal Products	103	10%
Electrical Appliances, and Components	103	18%
Transportation Equipment	103	20%
Computer and Electronic Products	65	26%
Fruit and Vegetable Preserving	239	42%
Textile Product Mills	92	52%
Foundries	231	69%
Food	212	76%
Paper	421	82%
Chemicals	574	82%



characteristics : low process energy, labour intensive



characteristics : low-medium process energy, few workers, each worker many lines



- halls with higher process load (>300 W/m²):

— processes are located outside the building enclosures

Industrial Halls ...



from manufacturing to retail, **Typical Hall** is a structure of:

- rectangular geometry, simple construction, with negligible amount of openings
- single floor of non-partitioned space (~ 4,000 m² on average)
- features such as daylighting, and PV could be readily deployed

100m x 40m x 6m

Multidisciplinary Approach

Demand side : energy demand heat gain, building construction
(insulation, airtightness,
daylighting ... etc) geometry,
climate

- **through Lowering Energy Demand**

Supply side : energy consumption building services equipment, in
particular, HVAC


- **through Efficient Delivery of Heating and Cooling**

Generation side: electricity and thermal PV, solar collector ... etc

- **together with Generation Technologies**

Energy Producing Halls

“Typical” Energy Producing Industrial Halls ...





with **Energy Saving**
and **Energy Generation**
measures

Aspects of the simulation models :


(based on the characteristics of industrial halls)

- ▶ **Single Zone** of non-partitioned space of uniformly distributed process load.
Investigation of single zone verse multi-zone model
- ▶ **Loose thermal comfort requirement** wide temperature setpoint range from 18°C to 30°C, no specific requirement in temperature fluctuation. **Comparison between unconditioned, loose thermal comfort, and comfort oriented halls**
- ▶ **Generalized scenarios** industry dependent process load, discrete occupancy patterns.
Future research : case specific scenario that involves varying occupancy pattern
- ▶ **Quantitative Approach** that investigates the performance due to varying the “quantity” rather than the “quality” of the element.

Investigation is about the Quantity




Real life issues :



- **Skylight** ► many different cost-effective ways to implement skylight. For modelling purposes,⁴⁰ just simple long strip of diffused double-glazing that could **distribute light evenly** on work surface. Only parameter is the **amount of skylight**.

Real life issues :





- **Multi-domains** ► for daylighting > 15% of roof area; saving in energy for lighting is roughly canceled out by heat gain or heat loss through skylight
- ASHRAE Standard 90.1 (2007) Prescriptive Building Envelope Option: skylight area < 5% gross roof area.

Real life technologies for heating/cooling

► Forced Ventilation for cooling


► **Transpired Solar Collectors (TSC)** for heating



► modeled in TRNSYS based on empirical relationship (of Tata Steel's product):

- solar radiation (W/m^2) on the surface
- flow rate (m^3/s) in the air gap per m^2 of the surface
- color / reflectance of the surface
- temperature of the heated air

Investigation is about the Quantity



Decision Support

What shall be the optimal (?) amount of insulation?


How large the roof area shall be covered by skylight?

Which parameters are most influential?

Quick Screening Tool

Sensitivity Analysis :

most influential parameters



Parameters and Scenarios (finally):

(that define configurations to be studied)

- ▶ **Climates** (mild - Amsterdam; cold - Shenyang, China; hot - Chennai, India)
- ▶ **Process Energy** (5, 25, 50, 125, 300 W/m²)
- ▶ **Occupancy** (1, 2, 3 shifts)
- ▶ **Insulation – roof** (1.5 to 4.5 R_{SI}, in 7 levels)
- ▶ **Insulation – wall** (1.5 to 4.5 R_{SI}, in 7 levels)
- ▶ **Thermal mass – roof** (none or 200 mm of concrete)
- ▶ **Thermal mass – wall** (none or 200 mm of concrete)
- ▶ **Skylight area** (daylighting, 0 to 15% of roof area, in 4 levels)
- ▶ **TSC** (heating, transpired solar collector, 0 to 100% of south wall, in 6 levels)
- ▶ **PV** (length of panel, 0.4-1.6m, in 4 levels; tilt angle, 0-56°, in 29 levels; number of rows, max. 40 rows in 40 levels)

Parameters and Scenarios :


(that define configurations to be studied)

- ▶ **Climates** (mild - Amsterdam; cold - Shenyang, China; hot - Chennai, India)
▶ **define Scenarios**
15 (3 climates x 5 processes) **scenarios**
- ▶ **Process Energy** (5, 25, 50, 125, 300 W/m²)
+ **retail space**
- ▶ **Occupancy** (1, 2, 3 shifts)
+ **unconditioned space**
- ▶ **Insulation – roof** (1.5 to 4.5 R_{SI}, in 7 levels)
- ▶ **Insulation – wall** (1.5 to 4.5 R_{SI}, in 7 levels)
- ▶ **Thermal mass – roof** (none or 200 mm of concrete)
▶ **define Configurations**
= 4704 configurations
per occupancy schedule
- ▶ **Thermal mass – wall** (none or 200 mm of concrete)
- ▶ **Skylight area** (daylighting, 0 to 15% of roof area, in 4 levels)
- ▶ **TSC** (heating, transpired solar collector, 0 to 100% of south wall, in 6 levels)
- ▶ **PV** (length of panel, 0.4-1.6m, in 4 levels; tilt angle, 0-56°, in 29 levels; number of rows, max. 40 rows in 40 levels)
▶ **energy generation**
investigated separately

Comprehensive Design Space

Evaluation

thousands of simulations ▶ **database**

- ▶ **Occupancy** (1, 2, 3 shifts)
 - ▶ **Insulation – roof** (1.5 to 4.5 R_{SI} , in 7 levels)
 - ▶ **Insulation – wall** (1.5 to 4.5 R_{SI} , in 7 levels)
 - ▶ **Thermal mass – roof** (none or 200 mm of concrete)
 - ▶ **Thermal mass – wall** (none or 200 mm of concrete)
 - ▶ **Skylight area** (daylighting, 0 to 15% of roof area, in 4 levels)
 - ▶ **TSC** (heating, transpired solar collector, 0 to 100% of south wall, in 6 levels)
- ▶ **define Configurations**
= 4704 configurations
per occupancy schedule
- 

Database of Energy Consumption :

ID	Schedule	Ins_Roof (R _s)	Ins_Wall (R _s)	Mass_Roof (m)	Mass_Wall (m)	Daylighting (% cov)	TSC (% coverage)
0	1	1.5	1.5	0.0	0.0	0	0
1	1	1.5	1.5	0.0	0.0	0	0
2	1	1.5	1.5	0.0	0.0	0	0
3	1	1.5	1.5	0.0	0.0	0	0
4	1	1.5	1.5	0.0	0.0	0	0
5	1	1.5	1.5	0.0	0.0	0	0
6	1	1.5	1.5	0.0	0.0	5	5
7	1	1.5	1.5	0.0	0.0	5	5
8	1	1.5	1.5	0.0	0.0	5	5
9	1	1.5	1.5	0.0	0.0	5	5
10	1	1.5	1.5	0.0	0.0	5	5
11	1	1.5	1.5	0.0	0.0	5	5
12	1	1.5	1.5	0.0	0.0	10	10
13	1	1.5	1.5	0.0	0.0	10	10
14	1	1.5	1.5	0.0	0.0	10	10
15	1	1.5	1.5	0.0	0.0	10	10
16	1	1.5	1.5	0.0	0.0	10	10
17	1	1.5	1.5	0.0	0.0	10	10
18	1	1.5	1.5	0.0	0.0	15	15
19	1	1.5	1.5	0.0	0.0	15	15
20	1	1.5	1.5	0.0	0.0	15	15
21	1	1.5	1.5	0.0	0.0	15	15
22	1	1.5	1.5	0.0	0.0	15	15
23	1	1.5	1.5	0.0	0.0	15	15
24	1	1.5	1.5	0.0	0.2	0	0
25	1	1.5	1.5	0.0	0.2	0	0
26	1	1.5	1.5	0.0	0.2	0	0
27	1	1.5	1.5	0.0	0.0	0	0
28	1	1.5	1.5	0.0	0.0	0	0

► **define Configurations**
= 4704 configurations
per occupancy schedule

Performance indicators :

Average)	Total Energy Consumption (kWh/m ² -yr)	Net CO ₂ Emission (kg CO ₂ /m ² -yr)	Annualized Relative Cash Flow (wrt. Baseline, €/m ²)
0	32.3	12.1	0.86
20	31.4	12.6	-6.82
40	30.3	13.2	-14.49
60	29.7	13.8	-22.18
80	29.2	14.5	-29.87
100	29.0	15.2	-37.57
0	25.7	9.5	1.01
20	25.0	10.1	-6.68
40	24.1	10.7	-14.35
60	23.5	11.4	-22.04
80	23.2	12.0	-29.74
100	22.9	12.7	-37.44
0	22.0	8.1	0.84
20	21.4	8.8	-6.85
40	20.6	9.4	-14.53
60	20.1	10.0	-22.22
80	19.7	10.7	-29.92
100	19.5	11.4	-37.62
0	19.9	7.4	0.47
20	19.4	8.1	-7.22
40	18.7	8.7	-14.91
60	18.3	9.4	-22.60
80	18.0	10.1	-30.30
100	17.7	10.8	-38.00
0	32.3	12.1	0.74
20	31.4	12.6	-6.82

► **Total Energy Consumption (operational)**

► **Net CO₂ Emission (operational + embodied)**

► **Annualized Relative Cash Flow (Operational + Investment)**

Database(s) :

► **six** input parameters :

- Insulation – roof (1.5 to 4.5 R_{Si} , in 7 levels)
- Insulation – wall (1.5 to 4.5 R_{Si} , in 7 levels)
- Thermal mass – roof (none or 200 mm of concrete)
- Thermal mass – wall (none or 200 mm of concrete)
- Skylight area (0 to 15% of roof area, in 4 levels)
- TSC (transpired solar collector, 0 to 100% of south wall, in 6 levels)

Ins_Roof (R_{Si})	Ins_Wall (R_{Si})	Mass_Roof (m)	Mass_Wall (m)	Daylighting (% cov)	TSC (% coverage)
1.5	1.5	0.0	0.0	0	0
1.5	1.5	0.0	0.0	0	20
1.5	1.5	0.0	0.0	0	40
1.5	1.5	0.0	0.0	0	60
1.5	1.5	0.0	0.0	0	80
1.5	1.5	0.0	0.0	0	100

► **three** performance indicators :

- Energy Consumption
- Net CO₂ Emission
- Annualized Relative Cash Flow

Total Energy Consumption (kWh/m ² -yr)	Net CO ₂ Emission (kg CO ₂ /m ² -yr)	Annualized Relative Cash Flow (wrt. Baseline, €/m ²)
32.3	12.1	0.86
31.4	12.6	-6.82
30.3	13.2	-14.49
29.7	13.8	-22.18
29.2	14.5	-29.87
29.0	15.2	-37.57
25.7	9.5	1.01
25.0	10.1	-6.68
24.1	10.7	-14.35

Schedule	Ins_Roof (R_{Si})	Ins_Wall (R_{Si})	Mass_Roof (m)	Mass_Wall (m)	Daylighting (% cov)	TSC (% coverage)	Total Energy Consumption (kWh/m ² -yr)	Net CO ₂ Emission (kg CO ₂ /m ² -yr)	Annualized Relative Cash Flow (wrt. Baseline, €/m ²)	Expected Risk (€/m ²)	Pareto_Solutions
1	1.5	1.5	0.0	0.0	0	0	32.3	12.1	0.86	-0.10	-
1	1.5	1.5	0.0	0.0	0	20	31.4	12.6	-6.82	-0.09	-
1	1.5	1.5	0.0	0.0	0	40	30.3	13.2	-14.49	-0.09	-
1	1.5	1.5	0.0	0.0	0	60	29.7	13.8	-22.18	-0.08	-
1	1.5	1.5	0.0	0.0	0	80	29.2	14.5	-29.87	-0.07	-
1	1.5	1.5	0.0	0.0	0	100	29.0	15.2	-37.57	-0.06	-
1	1.5	1.5	0.0	0.0	5	0	25.7	9.5	1.01	-0.04	P+
1	1.5	1.5	0.0	0.0	5	20	25.0	10.1	-6.68	-0.03	P
1	1.5	1.5	0.0	0.0	5	40	24.1	10.7	-14.35	-0.02	P

Economic and other assumptions	
Discount Rate (%)	4.59%
Life Cycle of Building (yr)	50
Cost of Electricity (€/kWh)	0.118
Cost of Gas (€/kWh)	0.040
CO ₂ Emission of Electricity Generation (kg CO ₂ /kWh)	0.415
CO ₂ Emission of Gas Consumption (kg CO ₂ /kWh)	0.202
Material Costs (€)	

Webtool

- valorization : the database was turned into a webtool by Bouwen met Staal, and will be updated soon

Tool energieverbruik hal

Geef de invoerparameters van de hal.

O-W N-Z

lengte breedte hoogte daglichttoetreding Rc waarde (dikte isolatie)

afb. Geometrie hal

Gebruik hal van 08.00 - 18.00

Proces energie [W/m²] 5 (distributie)

Kies afmeting van de hal [m] x [m] 20x60[m]

Orientatie hal (korte zijde) Noord-Zuid

Hoogte hal [m] 5[m]

Infiltratievoud 0.1 (doosvormig >10000m³ ZONDER dakramen en/of brandkleppen)

R_c-waarde gebouwschil 2

Daglichttoetreding dak [%] 0[%]

Bepaal energieverbruik



Invoer

Gebruik= 08.00-18.00

Procesenergie= 5 [W/m²]

Infiltratievoud= 0.1

R_c-waarde= 2.0 [m²K/W]

Daglichtopening= 0 [%]

Hoogte hal= 5 [m]



Orientatie Noord-Zuid (W= 20 [m], D= 60 [m])

Vast amount of data – Data Analysis :

to observe Design Trends (examples shown — warehouse 5W/m² process)

- ▶ Data Analysis for each scenario (process load)
- ▶ Design Trend for each Design Parameter
- ▶ unit in per operating hour to facilitate comparison among schedules (also to facilitate business decision, e.g. hourly wages, hourly production rate)



Total (Heating, Cooling, Ventilation, Lighting) Energy Consumption Per Occupied Hour



Cost Related Trends :

multi-objective consideration




- ▶ Trends depend on performance indicators
- ▶ Per occupied hour rate — capital investment (for energy saving measures) is more worthwhile if the facility is occupied for more shifts to spread out the cost



Material Choices

multi-objective consideration




- ▶ design decision might have greater impact on one objective but not the others
- ▶ steel or concrete?



Configurations :

put energy performance into perspective




- ▶ baseline building configuration is among the poorer performers under all schedules
- ▶ cooling is insignificant in a mild climate with a low process load (5 W/m²)



Configurations :

put energy performance into perspective

- ▶ lighting is the heaviest consumer. Most energy saving is due to daylighting.
- ▶ as process load increases, cooling can be significant



Conclusions

- ▶ industrial halls — high energy consumption, great energy production potential → requires a multidisciplinary and integrated design approach
- ▶ industrial halls in most cases — simple geometry and construction → **quick screening tool** to offer performance advice (driven by database based on pre-executed comprehensive design space evaluation)
- ▶ **life-cycle analysis** and **multi-objective considerations** provide fairer assessment on performance

THANK YOU



QUESTIONS

Side Note on Performance indicators :

Average)	Total Energy Consumption (kWh/m ² -yr)	Net CO ₂ Emission (kg CO ₂ /m ² -yr)	Annualized Relative Cash Flow (wrt. Baseline, €/m ²)
0	32.3	12.1	0.86
20	31.4	12.6	-6.82
40	30.3	13.2	-14.49
60	29.7	13.8	-22.18
80	29.2	14.5	-29.87
100	29.0	15.2	-37.57
0	25.7	9.5	1.01
20	25.0	10.1	-6.68
40	24.1	10.7	-14.35
60	23.5	11.4	-22.04
80	23.2	12.0	-29.74
100	22.9	12.7	-37.44
0	22.0	8.1	0.84
20	21.4	8.8	-6.85
40	20.6	9.4	-14.53
60	20.1	10.0	-22.22
80	19.7	10.7	-29.92
100	19.5	11.4	-37.62
0	19.9	7.4	0.47
20	19.4	8.1	-7.22
40	18.7	8.7	-14.91
60	18.3	9.4	-22.60
80	18.0	10.1	-30.30
100	17.7	10.8	-38.00
0	32.3	12.1	0.74
20	31.4	12.6	-6.82

► **Total Energy Consumption (operational)**

► **Net CO₂ Emission (operational + embodied)**

► **Annualized Relative Cash Flow (Operational + Investment)**

Total Energy Consumption :

Energy Demand

Heating Energy Demand

Cooling Energy Demand

Daylighting Supply

base heating demand with transpired solar collector that consumes energy for fans

supplementary heating demand fulfilled by infrared gas radiator, assumed gas of equivalent energy content

forced ventilation (energy for fans) + air-cooled chiller based on system efficiency curve of industrial partner

required amount of artificial lighting based on dimmable lighting characteristics

Energy Distribution

Electricity Consumption

Gas Consumption


Electricity Consumption

Electricity Consumption

fossil fuel offset based on site energy accounting

Total Energy Consumption (kWh/m²-yr)

Net CO₂ Emission :



CO ₂ emission factors (kg CO ₂ /kWh)	
Electricity consumption	0.415 <small>IEA (2012)</small>
Gas consumption	0.202 <small>IU (2010)</small>

Operational CO₂ Emission (kg CO₂)

Ins_Roof (R _{SI})	Ins_Wall (R _{SI})	Mass_Roof (m)	Mass_Wall (m)	Daylighting (% cov)	TSC (% coverage)
1.5	1.5	0.0	0.0	0	0
1.5	1.5	0.0	0.0	0	20
1.5	1.5	0.0	0.0	0	40
1.5	1.5	0.0	0.0	0	60
1.5	1.5	0.0	0.0	0	80
1.5	1.5	0.0	0.0	0	100

Material Carbon Footprint (kg CO ₂)	
Insulation (per R _{SI} per m ²)	2.4
Steel panel (per m ²)	12.3
Precast Concrete (per m ² , 0.2m thickness)	93.4
Skylight (per m ²)	93.0
TSC (per m ² of coverage)	12.3

Embodied Carbon Footprint (kg CO₂)

per unit area / annualized

Net CO₂ Emission (kg CO₂/m²-yr)

Annualized Relative Cash Flow :

$$I_A = I / \left[\frac{(1+r)^n - 1}{r(1+r)^n} \right]$$

r = discount rate
 n = number of years of the life-cycle
 I = initial capital investment

Amortized Relative Investment Cost = $\sum_m I_A - I_{A, \text{baseline building}}$
▶ relative to the baseline building

m = different energy saving and generation measures

Annual Relative Operating Cost = $\sum_{\text{utilities}} \left[\left(\text{Energy Consumption}_{\text{configuration}} - \text{Energy Consumption}_{\text{baseline}} \right) \times \text{Utility Prices} \right]$

Annualized Relative Cash Flow (€/m²) = - $\left(\text{Annual Amortized Relative Investment Cost} + \text{Annual Relative Operating Cost} \right)$

Annualized Relative Cash Flow :

$$I_A = I / \left[\frac{(1+r)^n - 1}{r(1+r)^n} \right]$$

r = discount rate
n = number of years of the life-cycle
I = initial capital investment

▶ why Amortized Cost ?

▶ why NOT Simply Payback Period ?

- ▶ does not account for the **financing cost**
- ▶ cannot handle cases, which **payback period > lifespan** of the equipment itself. For example, PV installation.
Performance beyond lifespan decreases significantly
- ▶ not correct to compare **different energy saving or generation measures of different lifespans** that are shorter than that of the building. Multiple cycles of a measure?

Annualized Relative Cash Flow :

$$I_A = I / \left[\frac{(1+r)^n - 1}{r(1+r)^n} \right]$$

r = discount rate

n = number of years of the life-cycle

I = initial capital investment

Amortized Relative Investment Cost

$$= \sum_m I_A - I_{A, \text{baseline building}}$$

► **relative to the baseline building**

↖ m = different energy saving and generation measures

► why relative ?

► cost of the **baseline building** (by definition. It can be anything common to standard practice) is what has to be or expected to be paid.

► concern about the additional **(relative)** cost. It can be LOWER than baseline building cost.

so what is the baseline building ?

- ▶ **Process Energy** (5, 25, 50, 125, 300 W/m²)
- ▶ **Occupancy** (1, 2, 3 shifts)
- ▶ **Insulation – roof** (1.5 to 4.5 R_{SI}, in 7 levels, **3.5 R_{SI}**)
- ▶ **Insulation – wall** (1.5 to 4.5 R_{SI}, in 7 levels, **3.5 R_{SI}**)
- ▶ **Thermal mass – roof** (none or 200 mm of concrete, **none**)
- ▶ **Thermal mass – wall** (none or 200 mm of concrete, **none**)
- ▶ **Skylight area** (daylighting, 0 to 15% of roof area, in 4 levels, **no skylight**)
- ▶ **TSC** (heating, transpired solar collector, 0 to 100% of south wall, in 6 levels, **no TSC**)
- ▶ **PV** (length of panel, 0.4-1.6m, in 4 levels; tilt angle, 0-56°, in 29 levels; number of rows, max. 40 rows in 40 levels)

Annualized Relative Cash Flow :

$$I_A = I / \left[\frac{(1+r)^n - 1}{r(1+r)^n} \right]$$

r = discount rate
 n = number of years of the life-cycle
 I = initial capital investment

Amortized Relative Investment Cost = $\sum_m I_A - I_{A, \text{baseline building}}$
▶ relative to the baseline building

m = different energy saving and generation measures

Annual Relative Operating Cost = $\sum_{\text{utilities}} \left[\left(\text{Energy Consumption}_{\text{configuration}} - \text{Energy Consumption}_{\text{baseline}} \right) \times \text{Utility Prices} \right]$

Annualized Relative Cash Flow (€/m²) = - $\left(\text{Annual Amortized Relative Investment Cost} + \text{Annual Relative Operating Cost} \right)$

Side Note on Unconditioned Halls :

design parameters

- considers multiple design parameters for different occupancy patterns

